

GE Power OEM

Track record 2010

Location of project

USA

Products/system used

Area 1 - Stator frame exterior

Interzinc[®] 52 @ 75-125 μ m (3-5 mils)

Intergard[®] 345 @ 100-175 μ m (4-7 mils)

Area 2 - Frame interior

Interlac[®] 789 @ 100-150 μ m (4-6 mils)

Project owner

GE Steam & Gas Generator

Applicator

General Electric

ISO12944 environment

C5-I

Surface preparation

SSPC-6

Total volume

22,712 litres (6,000 gals)

